Attestation

WELL Building Standard™

On the 10th of July 2023 for VOC emission and 3rd of April 2023 for VOC content, Eurofins Product Testing A/S received a sample of a grout with the product name:

Crocodile Premium Plus Tile Grout

supplied by

JORAKAY CORPORATION CO. LTD

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the CDPH 01350 (January 2017) and ASTM D2369-20 test standards (See test report no. 392-2023-00325303_H_EN and 392-2023-00172916_XG_EN).

The tested product complies with the requirements of WELL v2 Feature X06 VOC Restrictions: Part 1 by complying with:

VOC emissions specifications:

- The requirements of the CDPH 01350 v 1.2 (January 2017)

VOC content specifications:

- The requirement of South Coast Air Quality Management District (SCAQMD) Rule 1168 (2017) for “Ceramic Glass, Porcelain, & Stone Tile Adhesive” having a VOC content below 65 g/L.

7 September 2023

Laura Hartung Sørensen
Analytical Service Manager

Attestation

WELL Building Standard™

The International WELL Building Institute (IWBI) is a public benefit corporation whose mission is to improve human health and well-being in buildings and communities across the world through its WELL Building Standard (WELL). WELL™ and the related logo are trademarks owned by the IWBI and are used with permission.

Eurofins Product Testing A/S • Smedeskovvej 38, 8464 Galten, Denmark • Tel. +45 70 22 42 76

www.eurofins.dk/product-testing