Attestation

WELL Building Standard™

On the 25th of January 2024, Eurofins Product Testing A/S received a sample of paint with the product name:

Crocodile Skim Coat 102

supplied by

JORAKAY CORPORATION CO. LTD.

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the CDPH 01350 (January 2017) with EU LCI VOC threshold values and ASTM D2369-20 test standards (See test report no. 392-2024-00037505_H_EN and 392-2024-00037506_XG_EN).

The tested product complies with the requirements of WELL v2 Feature X06 VOC Restrictions: Part 1 by complying with:

VOC emissions specifications:

- The requirements of the CDPH 01350 v 1.2 (January 2017)

VOC content specifications:

- The requirement of SCAQMD Rule 1113 (Architectural coatings, 2016) for “trowel applied coating” having a VOC content below 50 g/L.

22 March 2024

Henriette Buch Lauersen
Analytical Service Manager

Laura Hartung Sørensen
Analytical Service Manager

The International WELL Building Institute (IWBI) is a public benefit corporation whose mission is to improve human health and well-being in buildings and communities across the world through its WELL Building Standard (WELL). WELL™ and the related logo are trademarks owned by the IWBI and are used with permission.