Attestation

WELL Building Standard™

On the 13th of April 2023, Eurofins Product Testing A/S received a sample of wall plaster with the product name:

Crocodile Skim Coat Smooth Gator

supplied by

JORAKAY CORPORATION CO., LTD.

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the CDPH 01350 (January 2017)/EN 16516 (2017) with EU LCI VOC threshold values and ASTM D2369-20 test standards (See test report no. 392-2023-10172923_H_EN and 392-2023-00172924_XG_EN).

The tested product complies with the requirements of WELL v2 Feature X06 VOC Restrictions: Part 1 by complying with:

VOC emissions specifications:

- The requirements of the CDPH 01350 v 1.2 (January 2017)

VOC content specifications:

- The requirement of SCAQMD Rule 1113 (Architectural coatings, 2016) for mastic coating having a VOC content below 100 g/L.

22 May 2023

Liva Kjær Hansen
Analytical Service Manager

Laura Hartung Sørensen
Analytical Service Manager

The International WELL Building Institute (IWBI) is a public benefit corporation whose mission is to improve human health and well-being in buildings and communities across the world through its WELL Building Standard (WELL). WELL™ and the related logo are trademarks owned by the IWBI and are used with permission.